

By Speed Post

F.NO.CP-11/58/2021-IPC-III-HO-CPCB-HO

3564

July 16, 2021

To,

M/s Ludhiana Beverage Pvt Ltd,
185 GT Road,
Ludhiana-141003,
Punjab

Sub: Inspection of M/s Ludhiana Beverage Pvt. Ltd, 185 GT Road, Ludhiana-141003, Punjab-Regd.

Sir,

It is to inform you that M/s Ludhiana Beverage Pvt. Ltd, 185 GT Road, Ludhiana-141003, Punjab was inspected by a team of CPCB officials on 24.06.2021 2021 to verify the compliance status of the industries under the special drive in catchment of River Sutlej within the jurisdiction of Punjab. Based on the observations made by the inspection team, the following recommendations are required to be complied by the unit:

1. The Unit shall install flow-meters at all the source of water abstraction (borewells) and submit the documentary evidences to CPCB at the earliest.
2. The Unit shall regularly operate its sludge filter-press.
3. The Unit shall not store any treated water/freshwater in the tube-settler.

In this context, it is requested to ensure compliance of the aforesaid recommendations of the inspection team and terms & conditions of the consent to operate granted by Punjab PCB and submit ATR to CPCB at the earliest.

This issues with the approval of the Competent Authority.

Yours faithfully,




(P.K. Mishra)
Additional Director &
Divisional Head- IPC-III

o/c

Copy to:

1. **The Member Secretary,** : With a request to keep this under surveillance for ensuring complete & continuous compliance of stipulated norms & terms & conditions of consent order
Punjab Pollution Control Board
(PPCB) Vatavaran Bhawan, Nabha
Road, Patiala - 147 001
2. **The Regional Director,** : For follow-up action please.
Regional Directorate, CPCB
Second Floor, Telephone Exchange,
Sector 49, Chandigarh - 160047



16/07/21
(P.K. Mishra)

केन्द्रीय प्रदूषण नियंत्रण बोर्ड
निर्गत.....
दिनांक..... 20/7/2021