

By Speed Post

F.No. CP-11/47/2021-IPC-III-HO-CPCB-HO/

July 16, 2021

To,

M/s Ashoka Dyeing &
Finishing Mills Pvt.Ltd,
C-132-133,Phase-5,
Focal Point, Ludhiana

Sub: Inspection of M/s Ashoka Dyeing & Finishing Mills Pvt.Ltd,C-132-133,Phase-5, Focal Point, Ludhiana-Regd.

Sir,

It is to inform you that M/s Ashoka Dyeing & Finishing Mills Pvt.Ltd,C-132-133,Phase-5, Focal Point, Ludhiana was inspected by a team of CPCB officials on 23.06.2021 to verify the compliance status of the industries under surprise inspection program. Based on the observations made by the inspection team, the following recommendations are required to be complied by the unit:

1. **The unit should install electromagnetic flow meter at the outlet of industrial unit as well as at the inlet of ETP and shall maintain proper logbook of the same. The unit shall submit copy of both the logbooks to CPCB.**
2. The unit should carry out adequacy assessment of its ETP through reputed organisations institutes preferably IIT/NIT/NEERI & submit the report in CPCB within 30 days of the receipt of this notice.
3. The unit should maintain good housekeeping practices.

In this context, it is requested to ensure compliance of the aforesaid recommendations of the inspection team and terms & conditions of the consent to operate granted by Punjab PCB and submit ATR to CPCB at the earliest.

This issues with the approval of the Competent Authority.

Yours faithfully,



(P.K. Mishra)
Additional Director &
Divisional Head- IPC-III

o/c

Copy to:

1. **The Member Secretary,** : With a request to keep this under surveillance for ensuring complete & continuous compliance of stipulated norms & terms & conditions of consent order
Punjab Pollution Control Board
(PPCB)Vatavaran Bhawan,
Nabha Road, Patiala - 147 001
2. **The Regional Director,** : For follow-up action please.
Regional Directorate, CPCB
Second Floor, Telephone
Exchange, Sector 49, Chandigarh
- 160047

16/07/21

(P.K. Mishra)

Handwritten notes and date: 20/7/2021

o/c