

CENTRAL POLLUTION CONTROL BOARD

Zonal Office (South) Nisarga Bhavan, Thimmaiah Road Shivanagar, Bangalore - 560 010

Inspection Report of M/s 110 MLD Kodungaiyur Sewage Treatment Plant Zone I & II

1	Name & Lo	ocation of STP	110 MLD Kodungaiyur STP- Zone I & II
			Chennai
2	STP constr	ructed by	Chennai Metropolitan Water Supply and
			Sewerage Board
3	Agency	for operation and	M/s VA Tech Wabag Ltd
	maintenan	ice of STP	-
4	Process of sewage treatment		Activated sludge process
5	Design capacity		110 MLD
6	Actual capacity		85-90 MLD
7	Description of treatment units		
	Primary	Volume	6860.11m ³
	settling	settling surface area	1960.03 m ³
	tank	Weir length	147.65 m
		retention period	2.82 hr
	Aeration	Volume	25255.08 m ³
	tanks	Retention period	5.5 hr
		MLSS & MLVSS, mg/l	2500-5000 mg/l
		Aeration capacity	37 KW/ 50 HP
		Rated aeration capacity	1.22 Kg O ₂ /KW hr
		Kg/KW hr	
	Secondar	Volume	8092.96 m ³
	y settling	settling surface area	2312.28 m ²
	tank	Weir length	319.81 m
		retention period	3.36 hr
	Activated sludge process		1042.406 m ³ /hr
	waste slud	ge generation	1042.406 111 / 111
	Sludge	Volume	3886.28 m ³
	Thickener	Thickening	1110.36 m ²
		surface	
	Sludge digester Volume		6074.48 m ³
8	Biogas produced if any		7000-7,500 m ³ /day of Biogas composed of 60-

		65% methane is produced
		Capacity of gas engine-1064 KW
9	Power generation if any	13-15 MW ₂ /day
		(2KWH/m ³ of biogas)
10	Point of treated sewage disposal	Secondary treated sewage is supplied to M/s
		Chennai Petroleum corporation Ltd, M/s
		Madras Fertilizer Ltd, M/s Manali
		Petrochemicals Ltd and Chennai Municipal
		Corporation for watering of plants.
		Remaining treated sewage is discharged into
		nearby water bodies.
11	Mode of sludge disposal	Grit and sludge from centrifuge are sent to
		Madurai Corporation composting site
40		maintained by Madurai corporation
12	Bypass arrangement of STP, if any	Though by-pass line provision is made in the
		pipeline from pumping station near river but
42		reported that no sewage is bypassed
13	Method of sludge disposal	sludge from STP is disposed in the landfill
		and solid from scrubber are bagged and given to CMWSSB
14	Dower requirement	
14	Power requirement	14.9 MW/day CMWSSB has imposed a condition that with
		operating agency that minimum 69% of power
		requirement should be met by Biogas, 17% by
		DG set and 14% from electricity board.
15	standby arrangement for power if	1000 KVA DG set
	any	1000 1171 50 300
16	Status of skilled/ trained	26 no.s trained manpower
	manpower	
17	Status of maintenance of log books	All maintenance log books are up to date
18	Status of laboratory	Facilities to analyse pH, TSS, COD, BOD, MLSS
		& MLVSS are available
\sim 1	. •	

Observations:

- Chennai Metropolitan Water Supply and Sewerage Board under Chennai city river conservation programme constructed Kodungaiyur Zone I & II STP of 110 MLD capacity during 2005-06.
- The facility was inspected by Sh. G. Dharmalingam, Sc-"C" during November, 2013
- The facility has adopted Activated Sludge Process with biogas generation for treatment of sewage. The settling tank is equipped with mechanical scrapper. The treated sewage from secondary clarifier is further polished in maturation ponds. The treatment flow diagram is placed as **Annexure-I**.
- The facility is spread out in a total area of 710 acres.